

Certificate

Order No. 20640247-10

Fire technical test of a halogen free wiring duct product,
according to DIN 54837 and classification
of the burning behaviour according to DIN 5510-2

Manufacturer: Shanghai Richeng Electronic Co.,Ltd
No. 555, Pinglin Road, Xinshen Industrial Area, Fengxian District,
Shanghai, P.R. China

Date of test / report: 05th & 11th of November 2013 / 12th of November 2013

Test specimen: Halogen Free Wiring Duct product, Trade name: RCCN, Material:
PC+ABS, Colour: Light Grey, Thickness: 2mm

Test specification: Examination according to DIN 54837 (12/2007)

Objective of test: Evaluation according to DIN 5510 part 2 (05/2009)

Test results:

Class of reaction to fire:	S 4
Class of drop behavior:	ST 1
Class of smoke emission	SR 2

DMT GmbH & Co. KG
Expert Body for Fire and Explosion Protection
Dortmund, 13th of November 2013



Mattausch



Püschel

This certificate is valid for the tested objects only. A transfer to other objects is not possible.

The test report for this certificate consists of 7 pages. The certificate is valid in conjunction with the report only.